

**Public Drinking Water:
Inoperable Community Water Systems (CWSs) Impacted by Hurricane Harvey
TCEQ Dataset 11.03.2017**

**Total Inoperable CWSs
(INOP or DESTROYED):**

2

Current Status	County	PWS ID	Facility Name	Population Served	Estimated Time to Restore	Comments
DESTROYED	Harris	1013459	BAREFOOT RV PARK	36	Months	The owner of Barefoot RV Park says that they are continuing to work on getting funding for repairs. They currently have not restored power to the park and have not replaced any of their lost water system equipment. Their water system is inoperable. They have ordered electrical poles so that they can restore power, and they will work on replacing the water system equipment once power is restored. TCEQ has supplied BWN mandatory language templates.
INOP	Harris	1010098	BEAUMONT PLACE	1,437	Months	TCEQ granted approval for the emergency interconnect between Beaumont Place and Harris County MUD 421, PWS#1013376. The TCEQ letter that granted approval was dated September 27, 2017. Beaumont Place is currently repairing the well at the Flagstaff plant. The well on Flagstaff Lane had a burned-up pump, motor, and wiring.
Totals:			2	1,473		