

**Wastewater:
Non-Operational Wastewater Facilities Impacted by Hurricane Harvey
TCEQ Dataset 11.03.2017**

**Total Non-Operational WW Facilities
(Current Status = NonOp):**

3

| County | Current Status | WW ID | Facility Name | Estimated Time to Restore | Comments | Population Served |
|----------------|----------------|----------|---|---------------------------|---|-----------------------|
| Harris | NonOp | 10932001 | HARRIS COUNTY - BEAR CREEK PIONEERS PARK WWTP | Weeks | Plant is now accessible by vehicle. Three (3) frac tanks aquired; tanks have been filled via temporary pumpout to hold them down in case of rain event. Control panel work with sewer and collection system wastewater from the on-site lift station. Hoping to pump and haul. All lift stations and plant were taken offline and turned off prior to storm on Friday 8/25. | 500 |
| Harris | NonOp | 11713001 | CEDAR BAYOU PARK UTILITY DISTRICT - CEDAR BAYOU PARK WWTP | Months | Flooded with 9 feet of water. All electrical pumps down. Currently sending wastewater to Baytown. They are considering shutting down the plant and sending waste water to Baytown permanently. Lift station has no power and has been cleaned out by Magnaflo. Plan to redo lift station and raise control panel. Getting rid of chlorine tanks on site. | Public Domestic WW |
| Harris | NonOp | 1160000 | U.S. ECO PARK | Months | Still offline. Placed an order for new aerator motors that are anticipated the end of this week. Cleanup project (oil release) still ongoing. Planning the cleanup project of the aeration basins and re-seeding the plant (coordinating with GCWDA to receive sludge). Cleaning and re-seeding of the aeration basins to be 11/06/2017, at the earliest. Receiving influent to the primary clarifier, storing wastewater in three clarifiers and an aeration basin. Discharging with chlorination when needed. | Industrial WW |
| Totals: | | | 3 | | | 500 |