

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Harris County Municipal Utility District No. 8 (CN600740450) operates Harris County Municipal Utility District No. 8 Wastewater Treatment Plant (RN102340148). a domestic wastewater treatment facility. The facility is located 556 1/2 Normandy Street, in Houston, Harris County, Texas 77015.

This application renewal to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 835,000 gallons per day.

Discharges from the facility are expected to contain treated domestic wastewater. Domestic wastewater will be treated by an activated sludge process using the complete mix/extended aeration mode. The Wastewater Treatment Plant treatment units include a rotary bar screen, aeration basin, clarifier, aerobic digester and a chlorine chamber. The effluent from the existing plant discharges thru a 36" pipe into Harris County Flood Control Unit No. P-100-00-00 Houston Ship Channel Tidal via Greens Bayou Tidal in (Segment #1006) of the San Jacinto River Basin. Sludge generated from the WWTP is dewatered and hauled away. A TCEQ permitted truck is used and sludge is disposed of per TCEQ regulations.

