

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Joseph Rd WWTP LLC (CN606145522) proposes to operate Maple Woods Wastewater Treatment Facility RN111747655. an activated sludge process plant operated in conventional mode. The facility will be located approximately 100 feet north of the intersection of Robin Hood Ln and King Richards Court, in Hockley, Waller County, Texas 77447.

This application is for the new permit to discharge at an annual average flow of 100,00 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and Escherichia coli. The domestic wastewater will be treated by *screening, aeration digestion, secondary clarification, and chlorination.*

RECEIVED
JUN 27 2023
Water Quality Applications Team